



# THE VILLAGE OF YORKVILLE, OHIO

Established 1916

## Sidewalk Concrete Specifications

- A. Meet ACI 318 (Current Edition) for all cast in place concrete
- B. **Concrete** 4,000 psi compressive 28-day strength; Air entrained 4 to 8 percent; Maximum slump of 4 inches; Type I normal Portland; Grey Color; Fine and Coarse Aggregates shall meet ASTM C33
- C. **Welded Steel Wire Fabric** 6 x 6 - W1.4 x W1.4; ANSI / ASTM A185; Uncoated Finish; Welded Wire Fabric shall be placed in the middle of the pavement slab
- D. **Finish** Light Broom
  
- E. **Expansion Joints** Provide 1/2 inch joint at 30 feet centers
- F. **Control Joints** Provide tooled joints at 5 feet centers
- G. **Slope** 1/4 inch per foot from center to the outside edges
- H. **Thickness** 4 inches
- I. **Width** Match existing / 3 feet minimum
- J. **Installation** Sidewalk shall be poured on 4 inches of compacted ODOT 304 on well compacted soil/base
  
- K. Sidewalk Facing the Street shall be even with the curb
- L. A Building Permit must be obtained by the Contractor or Property Owner before work begins.  
Building Permits may be obtained at the Yorkville City Building.  
Monday through Friday from 9:00 AM to 1:00 PM
- M. **All Curb Ramps** must meet ADA Guidelines / Requirements

**Thank You. Village of Yorkville Administration**

### Friendly Reminder

If Not Sure... Before You Pour.... Contact the Village Code Administrator

John Morelli (740) 859-2947